



## DANGEROUS GOODS SITE LICENCE

Issued in accordance with the *Dangerous Goods Safety Act 2004* and regulations  
 GST Exempt – (Div. 81)

**Chief Officer** Ross Stidolph

**Licence number** DGS021893

**Date of issue** 26/06/2014

**Expiry date** 26/06/2019

A0031/1

KLEN INTERNATIONAL (74) PTY LTD  
 PO BOX 529  
 WANNEROO WA 6946

**Business name and address for inspection** KLEN INTERNATIONAL (74) PTY LTD  
 36 HEMISPHERE ST  
 NEERABUP WA 6031

This licence authorises the holder to store dangerous goods within Western Australia in accordance with the application and any conditions, as specified below.

### Products

UN No.	Quantity (kL/t)	Depot type	Proper shipping name	Class / Division	Sub - risk	Packing group	Depot / Tank ID
	40 t	IDB	CORROSIVE SUBSTANCES OF PACKING GROUP II OR III	8			CORROSI VES BUNKER
	10 kL	IDB	FLAMMABLE LIQUIDS OF PACKING GROUP II OR III	3			FLAM LIQUID BUNKER
1350	10 t	IDB	SULFUR	4.1		III	FLAM SOLID BUNKER
	15 kL	IDB	FLAMMABLE LIQUIDS OF PACKING GROUP II OR III	3			FLAMM SOLID BUNKER
2291	50 t	PTP	LEAD COMPOUND, SOLUBLE, N.O.S.	6.1		III	FLUX MANUFA CTURE
	20 t	IDB	OXIDIZING SUBSTANCES OF PACKING GROUP II OR III	5.1			OXIDISIN G AGENT BUNK
2291	2100 t	IDB	LEAD COMPOUND, SOLUBLE, N.O.S.	6.1		III	WAREHO USE
2922	18 kL	PTP	CORROSIVE LIQUID, TOXIC, N.O.S.	8	6.1	III	WATER TREAT PLANT

**Legend**

kL	Kilolitres	IDA	IBCs (Intermediate Bulk Containers, generally 1000L or kg) outside of a building
t	Tonnes	IDB	IBCs within a building
Sub-risk	Subsidiary risk	PDA	Drum ramp or open area for package storage
BSS	Storage of loose solids in bulk	PDB	Normally a detached shed or building, with more than two walls, for package storage
ETD	Elevated tank (bottom of tank at least 2m above ground level)	PDC	Fully enclosed room within another building, for package storage
GTD	Tank normally at ground level	PTP	Process Plant
GTS	Self bunded ground tank	UTD	Underground tank

**Technical conditions**

OTHER	THE AGGREGATE QUANTITY OF DANGEROUS GOODS (SOLIDS OR LIQUIDS) IN THE CORROSIVES BUNKER MUST NOT EXCEED 40 T OR KL
OTHER	THE AGGREGATE QUANTITY OF DANGEROUS GOODS (SOLIDS OR LIQUIDS) IN THE OXIDISING AGENT BUNKER MUST NOT EXCEED 20 T OR KL
OTHER	THE SULPHUR OR FLAMMABLE LIQUIDS STORAGE SHALL BE MUTUALLY EXCLUSIVE IN THE CLASS 3/4.1 STORE

**Receipt**

Licence no.	DGS021893	Receipt no.	01-041272
Receipt date	27/05/2015	Amount	\$638.00